Federal Aviation Administration, DOT

- (3) A battery failure sensing and warning system with a means for disconnecting the battery from its charging source in the event of battery failure.
- (h) In the event of a complete loss of the primary electrical power generating system, the battery must be capable of providing at least 30 minutes of electrical power to those loads that are essential to continued safe flight and landing. The 30 minute time period includes the time needed for the pilots to recognize the loss of generated power and take appropriate load shedding action.

[Doc. No. 4080, 29 FR 17955, Dec. 18, 1964; 30 FR 258, Jan. 9, 1965, as amended by Amdt. 23–20, 42 FR 36969, July 18, 1977; Amdt. 23–21, 43 FR 2319, Jan. 16, 1978; Amdt. 23–49, 61 FR 5169, Feb. 9, 1996]

EFFECTIVE DATE NOTE: By Amdt. 23–62, 76 FR 75761, Dec. 2, 2011, §23.1353 was amended by revising paragraph (h), effective Jan. 31, 2012. For the convenience of the user, the revised text is set forth as follows:

§ 23.1353 Storage battery design and installation.

* * * * *

- (h)(1) In the event of a complete loss of the primary electrical power generating system, the battery must be capable of providing electrical power to those loads that are essential to continued safe flight and landing for:
- (i) At least 30 minutes for airplanes that are certificated with a maximum altitude of 25,000 feet or less; and
- (ii) At least 60 minutes for airplanes that are certificated with a maximum altitude over 25 000 feet.
- (2) The time period includes the time to recognize the loss of generated power and to take appropriate load shedding action.

§23.1357 Circuit protective devices.

- (a) Protective devices, such as fuses or circuit breakers, must be installed in all electrical circuits other than—
- (1) Main circuits of starter motors used during starting only; and
- (2) Circuits in which no hazard is presented by their omission.
- (b) A protective device for a circuit essential to flight safety may not be used to protect any other circuit.
- (c) Each resettable circuit protective device ("trip free" device in which the tripping mechanism cannot be over-

ridden by the operating control) must be designed so that—

- (1) A manual operation is required to restore service after tripping; and
- (2) If an overload or circuit fault exists, the device will open the circuit regardless of the position of the operating control.
- (d) If the ability to reset a circuit breaker or replace a fuse is essential to safety in flight, that circuit breaker or fuse must be so located and identified that it can be readily reset or replaced in flight.
- (e) For fuses identified as replaceable in flight—
- (1) There must be one spare of each rating or 50 percent spare fuses of each rating, whichever is greater; and
- (2) The spare fuse(s) must be readily accessible to any required pilot.

[Doc. No. 4080, 29 FR 17955, Dec. 18, 1964; 30 FR 258, Jan. 9, 1965, as amended by Amdt. 23–20, 42 FR 36969, July 18, 1977]; Amdt. 23–43, 58 FR 18976, Apr. 9, 1993

§ 23.1359 Electrical system fire protection.

- (a) Each component of the electrical system must meet the applicable fire protection requirements of §§ 23.863 and 23.1182.
- (b) Electrical cables, terminals, and equipment in designated fire zones that are used during emergency procedures must be fire-resistant.
- (c) Insulation on electrical wire and electrical cable must be self-extinguishing when tested at an angle of 60 degrees in accordance with the applicable portions of appendix F of this part, or other approved equivalent methods. The average burn length must not exceed 3 inches (76 mm) and the average flame time after removal of the flame source must not exceed 30 seconds. Drippings from the test specimen must not continue to flame for more than an average of 3 seconds after falling.

[Doc. No. 27806, 61 FR 5169, Feb. 9, 1996]

§23.1361 Master switch arrangement.

(a) There must be a master switch arrangement to allow ready disconnection of each electric power source from power distribution systems, except as provided in paragraph (b) of this section. The point of disconnection must be adjacent to the sources controlled